

Gulf County Building Department

<i>REQUIRED INSPECTIONS</i>	<i>DESCRIPTION</i>
TEMP POWER POLE	MUST HAVE 911 NUMBERS ON POLE
PILINGS	WOOD TREATMENT, LENGTH
FOOTER	MUST HAVE BOND WIRE FOR ELECTRIC AND REBAR
BLOCK STEEL	IF APPLICABLE HORIZONTAL REBAR AND LINTEL
ROUGH PLUMBING	DWV IN GROUND WITH WATER/AIR TEST
SLAB	COMPACTION, TERMITE TREATMENT, VAPOR BARRIER, WIRE MESH
FRAMING	BUILDING COMPONENTS INSTALLED, FASTENERS, STRAPS, AND CLIPS
WALL NAIL PATTERN	10 D NAILS 4" ON CENTER AT EDGES 6" IN FIELD
ROOF NAIL PATTERN	10 D NAILS 3" ON CENTER AT EDGES 6" IN FIELD
ROUGH IN	ELECTRICAL, MECHANICAL, & PLUMBING INSTALLED AND TESTED
INSULATION	MUST MEET EPI REQUIREMENTS
DRYWALL	5/8" TYPE X IN CEILINGS, 1/2" ON WALLS, 12" OC CEILINGS, 16" OC WALLS
TEMP/PERM POWER	GIVEN FULL POWER TO CHECK EQUIPMENT, 911 NUMBERS POSTED, EVERYTHING SHOULD BE SAFE
FINAL INSPECTION	BUILDING FULLY COMPLETED. FINAL SURVEY IF LESS THAN ONE ACRE, ELEVATION CERIFICATE IF IN A FLOOD ZONE, SEPTIC TANK FINAL APPROVAL, AND TERMITE CERTIFICATE